



# LOW VOLTAGE CABLE INSULATION TEST



CUSTOMER SAMPLE FORMS COMPANY PAGE \_\_\_\_\_

ADDRESS \_\_\_\_\_ JOB # FORMS-ALL

USER SAMPLE FORMS COMPANY

OWNER REPRESENTATIVE \_\_\_\_\_ TELEPHONE \_\_\_\_\_

DATE 5/7/2008 TEMPERATURE \_\_\_\_\_ °F HUMIDITY \_\_\_\_\_ % EQPT. LOCATION \_\_\_\_\_

SUBSTATION \_\_\_\_\_ CABLES \_\_\_\_\_ POSITION \_\_\_\_\_ GENERAL \_\_\_\_\_

MANUFACTURER \_\_\_\_\_ DATE MANUFACTURED \_\_\_\_\_

INSULATION TYPE 1:  TW  THW  THHW  XHHW  THHN EQUIPMENT TEMPERATURE \_\_\_\_\_ °C

INSULATION TYPE 2:  RH  RHW

OTHER \_\_\_\_\_

TEST VOLTAGE \_\_\_\_\_ KVDC TEMPERATURE CORRECTION FACTOR TO 20°C, TCF \_\_\_\_\_ INS. TYPE 1 \_\_\_\_\_ INS. TYPE 2 \_\_\_\_\_

IDENTIFICATION	NO. & COND. SIZE	FROM		PHASE									
		TO		A - GND	B - GND	C - GND	N - GND	A - B	B - C	C - A	A - N	B - N	C - N
			RDG										
			20 °C										
			RDG										
			20 °C										
			RDG										
			20 °C										
			RDG										
			20 °C										
			RDG										
			20 °C										
			RDG										
			20 °C										
			RDG										
			20 °C										
			RDG										
			20 °C										
			RDG										
			20 °C										

ALL INSULATION VALUES ARE IN MEGOHMS

COMMENTS:

DEFICIENCIES:

EQPT. INVENTORY NO. \_\_\_\_\_ TESTED BY: \_\_\_\_\_



# CABLE POLARIZATION INDEX (PI) TEST



CUSTOMER SAMPLE FORMS COMPANY PAGE \_\_\_\_\_  
 ADDRESS \_\_\_\_\_ JOB # FORMS-ALL  
 USER SAMPLE FORMS COMPANY  
 OWNER REPRESENTATIVE \_\_\_\_\_ TELEPHONE \_\_\_\_\_  
 DATE 5/7/2008 TEMPERATURE \_\_\_\_\_ °F HUMIDITY \_\_\_\_\_ % EQPT. LOCATION \_\_\_\_\_  
 SUBSTATION CABLES POSITION GENERAL

CABLE SOURCE \_\_\_\_\_ CABLE TERMINATION POINT \_\_\_\_\_  
 OPERATING VOLTAGE \_\_\_\_\_ kV INSTALLED IN \_\_\_\_\_ LENGTH \_\_\_\_\_ FT  
 MANUFACTURER \_\_\_\_\_ INSULATION TYPE \_\_\_\_\_ INSULATION THICKNESS \_\_\_\_\_ MILS  
 SIZE \_\_\_\_\_ KCMIL NO. OF CONDUCTORS \_\_\_\_\_ CONDUCTOR MATERIAL \_\_\_\_\_  
 RATED VOLTAGE \_\_\_\_\_ kV  GROUNDED  UNGROUNDED  BELTED  SHIELDED AGE \_\_\_\_\_  
 PHASE IDENTIFICATION: PHASE A \_\_\_\_\_ PHASE B \_\_\_\_\_ PHASE C \_\_\_\_\_

CONNECTED EQUIPMENT \_\_\_\_\_ CABLE TEMPERATURE \_\_\_\_\_ °C  
 TEST VOLTAGE \_\_\_\_\_ KVDC TEST VOLTAGE MULTIPLIER, K1 1.00 K2 = (K1)(TCF)  
 TEMPERATURE CORRECTION FACTOR TO 20 °C, TCF \_\_\_\_\_ TEST CONDUCTED  BEFORE  AFTER HIGH POTENTIAL TEST  
 K = INSULATION RESISTANCE CONSTANT IN MEGOHMS 20,000 d = INSIDE DIAMETER OF INSULATION \_\_\_\_\_  
 D = OUTSIDE DIAMETER OF INSULATION \_\_\_\_\_  $R = [ K \log_{10} \left( \frac{D}{d} \right) ] \left( \frac{1000}{L \text{ (ft)}} \right)$

MINUTES	PHASE A MEGOHMS				PHASE B MEGOHMS				PHASE C MEGOHMS			
	RDG	RANGE MULT	K2	20 °C	RDG	RANGE MULT	K2	20 °C	RDG	RANGE MULT	K2	20 °C
0.25												
0.50												
0.75												
1.00												
1.25												
1.50												
1.75												
2.00												
2.50												
3.00												
4.00												
5.00												
6.00												
7.00												
8.00												
9.00												
10.00												
P.I. NO.*												

\* POLARIZATION INDEX = 10 MINUTE READING / 1 MINUTE READING

MINIMUM DESIGN INSULATION RESISTANCE, R = \_\_\_\_\_ MEGOHMS

COMMENTS:   
 DEFICIENCIES:

EQPT. INVENTORY NO. \_\_\_\_\_ TESTED BY: \_\_\_\_\_




# CABLE POLARIZATION INDEX (PI) TEST



PAGE \_\_\_\_\_

## POLARIZATION CURVE



- Phase A: Red Square
- Phase B: Blue Circle
- Phase C: Green Triangle



# VLF CABLE TEST



CUSTOMER SAMPLE FORMS COMPANY PAGE \_\_\_\_\_  
 ADDRESS \_\_\_\_\_ JOB # FORMS-ALL  
 USER SAMPLE FORMS COMPANY  
 OWNER REPRESENTATIVE \_\_\_\_\_ TELEPHONE \_\_\_\_\_  
 DATE 5/7/2008 TEMPERATURE \_\_\_\_\_ °F HUMIDITY \_\_\_\_\_ % EQPT. LOCATION \_\_\_\_\_  
 SUBSTATION CABLES POSITION GENERAL

OPERATING VOLTAGE \_\_\_\_\_ kV INSTALLED IN  CONDUIT  TRAY LENGTH \_\_\_\_\_ FT CABLE TEMPERATURE \_\_\_\_\_ °C  
 MANUFACTURER \_\_\_\_\_ INSULATION TYPE \_\_\_\_\_ INSULATION THICKNESS \_\_\_\_\_ MILS  
 SIZE \_\_\_\_\_ MCM NO. OF CONDUCTORS \_\_\_\_\_ CONDUCTOR MATERIAL  CU  AL  
 RATED VOLTAGE \_\_\_\_\_ kV  GROUNDED  SHIELDED  BELTED AGE \_\_\_\_\_  
 UNGROUNDED  UNSHIELDED (PILC)  
 RESISTANCE GROUND  CONCENTRIC NEUTRAL  
 CABLE SOURCE \_\_\_\_\_ CABLE TERMINATION POINT \_\_\_\_\_  
 CONNECTED EQUIPMENT \_\_\_\_\_ ISOLATE CABLE  Y  N  ARRESTERS  POT FUSES  
 NUMBER OF MANHOLES \_\_\_\_\_ NUMBER OF TERMINATIONS \_\_\_\_\_ NUMBER OF SPLICES \_\_\_\_\_  
 TERMINATION / SPLICES  HAND TAPED  3-M TERM. KIT  RAYCHEM KIT  OTHER \_\_\_\_\_

RMS TEST VOLTAGE \_\_\_\_\_ kV BREAKDOWN  YES  NO PLANNED TEST DURATION \_\_\_\_\_ START TIME \_\_\_\_\_  
 TEST FREQUENCY \_\_\_\_\_ Hz TIME TO FAILURE \_\_\_\_\_ MIN  1 MIN  15 MIN  30 MIN  60 MIN  
 SHIELD RESISTANCE A-B \_\_\_\_\_ OHMS B-C \_\_\_\_\_ OHMS C-A \_\_\_\_\_ OHMS  
 WAVE SHAPE  SINE  COSINE / RECTANGULAR  OTHER \_\_\_\_\_ END TIME \_\_\_\_\_  
 TEST TYPE  WITHSTAND  PASS / FAIL  DIAGNOSTIC SEE COMMENT BELOW

PHASE A OR  PHASE A, B, C

PHASE B

PHASE C

TESTS (MINUTES)	<input type="checkbox"/> PHASE A OR <input type="checkbox"/> PHASE A, B, C			<input type="checkbox"/> PHASE B			<input type="checkbox"/> PHASE C		
	MEGOHMS	NANO FARADS	MICRO AMPS	MEGOHMS	NANO FARADS	MICRO AMPS	MEGOHMS	NANO FARADS	MICRO AMPS
1									
5									
10									
15									
20									
25									
30									
45									
60									

COMMENTS: \_\_\_\_\_  
 DEFICIENCIES: \_\_\_\_\_

EQPT. INVENTORY NO. \_\_\_\_\_ TESTED BY: \_\_\_\_\_



# TAN DELTA CABLE TEST



CUSTOMER SAMPLE FORMS COMPANY PAGE \_\_\_\_\_  
 ADDRESS \_\_\_\_\_ JOB # FORMS-ALL  
 USER SAMPLE FORMS COMPANY  
 OWNER REPRESENTATIVE \_\_\_\_\_ TELEPHONE \_\_\_\_\_  
 DATE 5/7/2008 TEMPERATURE \_\_\_\_\_ °F HUMIDITY \_\_\_\_\_ % EQPT. LOCATION \_\_\_\_\_  
 SUBSTATION CABLES POSITION GENERAL

OPERATING VOLTAGE \_\_\_\_\_ kV INSTALLED IN  CONDUIT  TRAY LENGTH \_\_\_\_\_ FT CABLE TEMPERATURE \_\_\_\_\_ °C  
 MANUFACTURER \_\_\_\_\_ INSULATION TYPE \_\_\_\_\_ INSULATION THICKNESS \_\_\_\_\_ MILS  
 SIZE \_\_\_\_\_ MCM NO. OF CONDUCTORS \_\_\_\_\_ CONDUCTOR MATERIAL  CU  AL  
 RATED VOLTAGE \_\_\_\_\_ kV  GROUNDED  SHIELDED  BELTED (PILC) AGE \_\_\_\_\_  
 UNGROUNDED  UNSHIELDED  
 RESISTANCE GROUND  CONCENTRIC NEUTRAL  
 CABLE SOURCE \_\_\_\_\_ CABLE TERMINATION POINT \_\_\_\_\_  
 CONNECTED EQUIPMENT \_\_\_\_\_ ISOLATE CABLE  Y  N  ARRESTERS  POT FUSES  
 NUMBER OF MANHOLES \_\_\_\_\_ NUMBER OF TERMINATIONS \_\_\_\_\_ NUMBER OF SPLICES \_\_\_\_\_  
 TERMINATION / SPLICES  HAND TAPED  3-M TERM. KIT  RAYCHEM KIT  OTHER \_\_\_\_\_

SYSTEM VOLTAGE \_\_\_\_\_ BREAKDOWN  YES  NO PLANNED TEST DURATION PER STEP \_\_\_\_\_ START TIME \_\_\_\_\_  
 TEST FREQUENCY \_\_\_\_\_ TIME TO FAILURE \_\_\_\_\_ MIN  1 MIN  5 MIN  10 MIN  
 WAVE SHAPE  SINE  COSINE / RECTANGULAR  OTHER \_\_\_\_\_ END TIME \_\_\_\_\_  
 TEST TYPE  WITHSTAND  PASS / FAIL  DIAGNOSTIC

PHASE A OR  PHASE A, B, C  PHASE B  PHASE C

TEST VOLTAGE kV		TAN DELTA	NANO FARADS	MICRO AMPS	TAN DELTA	NANO FARADS	MICRO AMPS	TAN DELTA	NANO FARADS	MICRO AMPS
5kV CABLE	15 kV CABLE									
1.0	2									
1.5	3.5									
2.0	5									
2.4	7									

COMMENTS: \_\_\_\_\_  
 DEFICIENCIES: \_\_\_\_\_

EQPT. INVENTORY NO. \_\_\_\_\_ TESTED BY: \_\_\_\_\_



# CABLE HIGH POTENTIAL TEST




CUSTOMER SAMPLE FORMS COMPANY PAGE \_\_\_\_\_  
 ADDRESS \_\_\_\_\_ JOB # FORMS-ALL  
 USER SAMPLE FORMS COMPANY  
 OWNER REPRESENTATIVE \_\_\_\_\_ TELEPHONE \_\_\_\_\_  
 DATE 5/7/2008 TEMPERATURE \_\_\_\_\_ °F HUMIDITY \_\_\_\_\_ % EQPT. LOCATION \_\_\_\_\_  
 SUBSTATION CABLES POSITION GENERAL

CABLE SOURCE \_\_\_\_\_ CABLE TERMINATION POINT \_\_\_\_\_  
 OPERATING VOLTAGE \_\_\_\_\_ kV INSTALLED IN \_\_\_\_\_ LENGTH \_\_\_\_\_ FT  
 MANUFACTURER \_\_\_\_\_ INSULATION TYPE \_\_\_\_\_ INSULATION THICKNESS \_\_\_\_\_ MILS  
 SIZE \_\_\_\_\_ KCML NO. OF CONDUCTORS \_\_\_\_\_ CONDUCTOR MATERIAL \_\_\_\_\_  
 RATED VOLTAGE \_\_\_\_\_ kV  GROUNDED  UNGROUNDED  BELTED  SHIELDED AGE \_\_\_\_\_

CONNECTED EQUIPMENT \_\_\_\_\_

TIME MINUTES	TEST VOLTAGE	PHASE A μA	PHASE B μA	PHASE C μA
0.25				
0.50				
0.75				
1.00				
1.25				
1.50				
1.75				
2.00				
3.00				
4.00				
5.00				
6.00				
7.00				
8.00				
9.00				
10.00				
11.00				
12.00				
13.00				
14.00				
15.00				
16.00				
17.00				
18.00				
19.00				
20.00				
21.00				
22.00				
23.00				
24.00				
25.00				
DECAY TO 5kV; SECS				
SHIELD RESIST.- OHMS				



COMMENTS: \_\_\_\_\_  
 DEFICIENCIES: \_\_\_\_\_

EQPT. INVENTORY NO. \_\_\_\_\_ TESTED BY: \_\_\_\_\_





# CABLE HIGH POTENTIAL TEST AND INSULATION RESISTANCE



CUSTOMER SAMPLE FORMS COMPANY PAGE \_\_\_\_\_

ADDRESS \_\_\_\_\_ JOB # FORMS-ALL

USER SAMPLE FORMS COMPANY

OWNER REPRESENTATIVE \_\_\_\_\_ TELEPHONE \_\_\_\_\_

DATE 5/7/2008 TEMPERATURE \_\_\_\_\_ °F HUMIDITY \_\_\_\_\_ % EQPT. LOCATION \_\_\_\_\_

SUBSTATION CABLES POSITION GENERAL

CABLE SOURCE \_\_\_\_\_ CABLE TERMINATION POINT \_\_\_\_\_

OPERATING VOLTAGE \_\_\_\_\_ kV INSTALLED IN \_\_\_\_\_ LENGTH \_\_\_\_\_ FT


MANUFACTURER \_\_\_\_\_ INSULATION TYPE \_\_\_\_\_ INSULATION THICKNESS \_\_\_\_\_ MILS

SIZE \_\_\_\_\_ KCMIL NO. OF CONDUCTORS \_\_\_\_\_ CONDUCTOR MATERIAL \_\_\_\_\_

RATED VOLTAGE \_\_\_\_\_ kV  GROUNDED  UNGROUNDED  BELTED  SHIELDED AGE \_\_\_\_\_

CONNECTED EQUIPMENT \_\_\_\_\_

TIME MINUTES	TEST kV	PHASE A $\mu$ A	PHASE B $\mu$ A	PHASE C $\mu$ A
0.25				
0.50				
0.75				
1.00				
1.25				
1.50				
1.75				
2.00				
3.00				
4.00				
5.00				
6.00				
7.00				
8.00				
9.00				
10.00				
11.00				
12.00				
13.00				
14.00				
15.00				
16.00				
17.00				
18.00				
19.00				
20.00				
21.00				
22.00				
23.00				
24.00				
25.00				
DECAY TO 5kV; SECS				
SHIELD RESIST.- OHMS				
INSULATION RESISTANCE		GIGA-OHMS @ _____ kV		
		0.000	0.000	0.000



COMMENTS:

DEFICIENCIES:

EQPT. INVENTORY NO. \_\_\_\_\_ TESTED BY: \_\_\_\_\_




# TIME DOMAIN REFLECTOMETER



CUSTOMER SAMPLE FORMS COMPANY PAGE \_\_\_\_\_  
 ADDRESS \_\_\_\_\_ JOB # FORMS-ALL  
 USER SAMPLE FORMS COMPANY  
 OWNER REPRESENTATIVE \_\_\_\_\_ TELEPHONE \_\_\_\_\_  
 DATE 5/7/2008 TEMPERATURE \_\_\_\_\_ °F HUMIDITY \_\_\_\_\_ % EQPT. LOCATION \_\_\_\_\_  
 SUBSTATION \_\_\_\_\_ CABLES \_\_\_\_\_ POSITION \_\_\_\_\_ GENERAL

**Select the Memory Locations to Download**

1  2  3  4  5  6  7  8  9  10  11  12  13  14  15



Time

MEMORY LOCATION	WAVE TYPE	METER RANGE	PULSE WIDTH (ns)	GAIN (dB)	VELOCITY FACTOR	TRACE STYLE	DATE
-----------------	-----------	-------------	------------------	-----------	-----------------	-------------	------

COMMENTS: \_\_\_\_\_  
 DEFICIENCIES: \_\_\_\_\_

EQPT. INVENTORY NO. \_\_\_\_\_ TESTED BY: \_\_\_\_\_



# BUS DUCT INSULATION TEST



CUSTOMER SAMPLE FORMS COMPANY PAGE \_\_\_\_\_

ADDRESS \_\_\_\_\_ JOB # FORMS-ALL

USER SAMPLE FORMS COMPANY

OWNER REPRESENTATIVE \_\_\_\_\_ TELEPHONE \_\_\_\_\_

DATE 5/7/2008 TEMPERATURE \_\_\_\_\_ °F HUMIDITY \_\_\_\_\_ % EQPT. LOCATION \_\_\_\_\_

SUBSTATION CABLES POSITION GENERAL

MANUFACTURER \_\_\_\_\_ TYPE \_\_\_\_\_ VOLTAGE CLASS \_\_\_\_\_

VERTICAL RATING \_\_\_\_\_ A HORIZONTAL RATING \_\_\_\_\_ A NEUTRAL RATING \_\_\_\_\_ A GROUND RATING \_\_\_\_\_ A

CONFIGURATION 3 WIRE  4 WIRE  5 WIRE  CONDUCTOR COPPER  ALUMINUM  DATE MANUFACTURED \_\_\_\_\_

CATALOG NO. \_\_\_\_\_ SERIAL NO. \_\_\_\_\_ CURRENT WITHSTAND RATING \_\_\_\_\_ kA

TEST VOLTAGE \_\_\_\_\_ KVDC EQUIPMENT TEMPERATURE \_\_\_\_\_ °C TEMPERATURE CORRECTION FACTOR TO 20 °C, TCF \_\_\_\_\_

IDENTIFICATION	FROM	PHASE									
	TO	A - GND	B - GND	C - GND	N - GND	A - B	A - C	B - C	A - N	B - N	C - N

ACTUAL READING / SHADING INDICATES TEMPERATURE CORRECTED VALUES ALL INSULATION VALUES ARE IN MEGOHMS

COMMENTS: \_\_\_\_\_

DEFICIENCIES: \_\_\_\_\_

EQPT. INVENTORY NO. \_\_\_\_\_ TESTED BY: \_\_\_\_\_

